



South Davis Water District

407 West 3100 South • Bountiful, UT. 84010
(801) 295-4468 • sdwoffice@southdaviswater.us

CONSUMER 2018 CONFIDENCE REPORT

We're pleased to present you with a look at the quality of the water delivered in 2018. Also included in this report is a look at where your water comes from, what we are doing to protect your water, how it compares to EPA and State of Utah standards, and possible sources of contamination, some tips on maintaining safe water in your home, and how you can help conserve this precious resource. The South Davis Water District is committed to providing you with safe, clean drinking water.

WHERE YOUR WATER COMES FROM

SDWD's drinking water comes from 1 spring, 5 wells, and 1 surface water treatment plant that treats water from the Weber River. The treatment plant is operated by the Weber Basin Conservancy District. The SDWD, like other public water suppliers in the area, purchases some of its

culinary water from Weber Basin on a contractual basis. Although the SDWD has more than enough water rights and pumping ability to supply the entire District with water from springs and wells; this treated surface water was contracted for in the 50's during the Weber Basin Project, and is therefore in a "use it or lose it" state and must be used. The District uses all of this contractual water each year while supplementing it with SDWD's own sources.



Our spring water is collected underground and diverted into holding tanks. The Enoch Spring provides millions of gallons to the eastern bench area of the District in Bountiful. The Enoch spring is a free source of fresh, clean, great tasting water.

Our North Canyon, Bona Vista, and Val Verda (currently being rehabilitated) wells provide water to the eastern portion of Bountiful and North Salt Lake areas that reside within the SDWD. Water is boosted from these wells to two large tanks at higher elevations named 1A and 2A, where it is held for consumption. This water is both chlorinated and fluoridated before it enters these tanks.

Our three Val Vista Wells pump water to a large tank located in the middle of the District called 3A. This reservoir serves the lower/middle portion of the District in Bountiful as well as an easterly portion of Woods Cross. Water from the treatment plant is fed directly into the District's distribution system via a connection located at 3100 S. and Orchard Dr. This water is occasionally boosted from this location up to the 3A tank as the need arises, but the majority of this water serves the bottom portion of the District.

The District also sold 141,500,000 gallons of water to Bountiful City in 2018 while construction continued on their treatment plant.

The chart below shows the number of gallons consumed from each source and the percentage each source contributed.

SOURCE	GALLONS	%TOTAL
North Canyon Well	138,613,190	32.9%
Bona Vista Well	6,612,739	1.6%
Val Vista Well #1	25,546,276	6.1%
Val Vista Well #2	23,287,486	5.5%
Val Vista Well #3	39,452,680	9.4%
Enoch Spring	22,320,600	5.3%
Surface Water Treatment Plant	165,520,000	39.2%

SOURCE PROTECTION AND SUSCEPTIBILITY

The SDWD has a Drinking Water Source Protection Plan that can be viewed at our office. It provides information such as potential sources of contamination and our designated source protection areas. The source protection zones for each well and spring are estimated based on the time it takes a drop of water to travel to the well or spring collection point. All of the wells in the SDWD have surface grout seals that are in good condition as well as an impervious clay layer over the Enoch spring that has been found to be in good condition.

The layers of sediment above the portions of the aquifer in our area that we pull water from are classified as

unconfined. Unconfined refers to the ability of the formation to allow potential contamination from surface activity. Unconfined aquifers are susceptible because they do not have a barrier such as a clay layer that protects the aquifer from exposure to the surface.

Common household chemicals pose a great risk to aquifers. Paints, cleaners, motor oil, gasoline, antifreeze, and lawn & garden chemicals that are disposed of in the gutter or backyard can migrate to rivers and streams or filter down through the ground and pollute aquifers.

Residents can help to prevent water pollution by employing best management practices when storing, using, and discarding fertilizers, pesticides, and other household hazardous wastes properly.

The types of prioritized potential contamination sources, with #1 being highest risk of affecting the wells and springs, are as follows:

1. Residential and commercial pesticide, herbicide, and fertilizer use.
2. Residential sewer system leakages.
3. Streets and roadways - transport spills and road clearing with deicing salts.
4. Existing and abandoned wells that have become contaminated.

Use the following guidelines when using pesticides, herbicides, and fertilizers:

- **ONLY PURCHASE THE AMOUNT AND KIND OF FERTILIZER OR PESTICIDE NEEDED AND STORE IN LOCKED DRY CABINETS.**
- **DO NOT ALLOW FERTILIZER AND PESTICIDE SPILLS TO BE WASHED INTO THE STORM DRAIN SYSTEM.**
- **DRY PESTICIDE AND FERTILIZER SPILLS SHOULD BE SWEEPED UP AND LATER APPLIED AT THE RATE SPECIFIED ON AN AREA WHERE NEEDED.**
- **LIQUID PESTICIDE AND FERTILIZER SPILLS SHOULD BE SOAKED UP USING ABSORBENT MATERIAL (SUCH AS SAWDUST, CAT LITTER, OR SOIL) AND THEN TAKEN TO A HOUSEHOLD HAZARDOUS WASTE COLLECTION SITE.**
- **NEVER APPLY FERTILIZERS NEAR WELLS.**
- **DO NOT SPRAY OR APPLY PESTICIDES NEAR WALKS OR DRIVEWAYS. THIS WILL HELP PREVENT PESTICIDES FROM WASHING OFF INTO THE STORM DRAIN SYSTEM.**



Household hazardous wastes (HHWs) are discarded materials that are ignitable, corrosive, reactive, and toxic or otherwise listed as hazardous by the EPA. Paint, used motor oil, gasoline, antifreeze, or lawn and garden chemicals that are disposed of in the gutter or your backyard can migrate to rivers or filter down through the ground and pollute aquifers. The following best management practices should be employed when handling HHWs:

- **COMPLETELY USE THE PRODUCT BEFORE DISPOSING OF THE CONTAINER.**
- **RETURN UNUSED PORTIONS TO COMMUNITY HOUSEHOLD HAZARDOUS WASTE COLLECTION PROGRAMS.**
- **DO NOT FLUSH HHWs DOWN THE TOILET, DOWN THE SINK, DOWN A STORM DRAIN, OR POUR ON THE GROUND.**

Please don't spoil the water supply for yourself and everyone else! Dispose of paint, used motor oil, and other hazardous chemicals in a proper and safe manner. You can call the Division of Environmental Health at 801-944-6697 for the nearest location for hazardous waste disposal.



If you would like additional information on best management practices please visit the Utah Division of Drinking Water website at www.drinkingwater.utah.gov/source_protection_intro.htm for links to Fact Sheets describing ways to minimize the impact of potential contamination sources on our water resources.



SURFACE WATER TREATMENT PROCESS

As stated above, the SDWD received 39.2% of its drinking water in



2018 from a surface water treatment plant.

Coagulation and flocculation is the first step in the treatment process. The goal of this stage is to bind up the suspended particles in the raw water by adding a coagulant as it first enters the water treatment plant. Floc, which is a tuft-like aggregate, is produced from the mixing of the coagulant in the raw water. Over time, as more suspended matter is bound, the smaller aggregates of floc become larger particles of floc.

Sedimentation is the second stage of water treatment. The objective of this stage is to remove the floc. This is accomplished as the floc settles out of the water in long sedimentation basins. The cleaner water is drained off the surface of the sedimentation basin and sent to the next stage.

Filtration is the third stage of water treatment. The purpose of this stage is to remove the remaining suspended particles and dissolved constituents. This is accomplished by passing the water through a filter composed of different layers of sand and gravel.

Disinfection is the fourth stage of water treatment. A small amount of chlorine, or other disinfecting chemical, is added. This is used to kill any remaining germs and to keep the water safe as it travels to the public. This treatment process removes cryptosporidium and giardia from the water; however, it cannot guarantee that 100% of the microbes are removed. Monitoring by Weber Basin indicates the presence of cryptosporidium and giardia in the source water. Current testing methods don't allow them to determine if


the organisms are dead or if they are capable of causing disease. Therefore, UV light is administered to the water in order to prevent these microbes, if they are present, from reproducing and causing sickness.

Microfiltration uses a physical filtration process where surface water is passed through a special pore-sized membrane to separate microorganisms and suspended particles. The use of microfiltration membranes presents a physical means of separation, a barrier, as opposed to a chemical coagulant. Disinfection is applied again as the final stage of the process.

WATER CONSERVATION

With ever increasing growth and the nature of the regional climate, there is no question that we will encounter future drought years. Future drought cycles will have an even greater effect than previous drought because of the increased population and higher demands on water systems. Conservation and improved water efficiency needs to become a way of life for all of us by incorporating better water use practices and valuing this precious resource more than ever.

The South Davis Water District is committed to conserving. The District has strongly enforced the watering time policy, which is, residents cannot water between 10:00 a.m. and 6:00 p.m. As the below chart shows, irrigation water usage has slowly declined over the years, but is still extremely high.



After taking out estimated operational water loss of 10%, the District is still using 2.2 acre feet of water per acre of irrigable land. That is extremely high and must be reduced.

Please use irrigation water responsibly before the District is forced to meter it.

WATER QUALITY INSIDE YOUR HOME

Once the water passes from our system and through the meter, you become a partner with us in making sure it stays fresh and clean. Here are some things to consider.

Water Heater

Check the temperature setting for your water heater. Water that is too hot can create a burn hazard, while water that is too cool can create a perfect environment for bacteria to grow. You may also want to consider installing a pressure regulator to prevent any sudden surges to your water heater. These can be found at any general plumbing supply store, or you can have a plumber install one for you.



Filters and Purifiers

All types of filters and purifiers (point of use devices) need to be properly maintained and monitored. Neglected devices may not work as intended; become a haven for microbial growth; or shed filter material into your home's tap water. Even the filter in your refrigerator needs to be properly maintained to protect your family.



Water Softeners

Since the hardness of your water can range anywhere from 14 to 30 grains per gallon, it is important to monitor the settings on your water softener regularly to make sure that you are treating your water properly. Over treating your water is wasted money while under treating is not effective.


Unused Rooms

If you have a kitchen or bathroom that rarely gets used, you should make a point of running water through the faucets on a frequent basis. Stagnant pipes and fixtures are susceptible to microbial growth. Flushing unused water lines regularly will help prevent this.

BACKFLOW & CROSS-CONNECTION

A backflow event is when water that is potentially contaminated is pushed or drawn into a culinary water supply.

One type of backflow event can be created through a high pressure contaminated source pushing into a clean potable source. An example of this occurrence could be a dentist office using a suction device which uses a water pump creating a venturi effect by accelerating the water through pressurization. If the suction device does not have a proper backflow device installed, this pressurized, contaminated water could enter the culinary supply.



Another type of backflow event can be created by a negative pressure or suction effect. One example could be a culinary sprinkler system tied into the home's culinary service line without a backflow assembly and the residents use enough water in the house that there is a vacuum created sucking air through the sprinkler heads, contaminating the resident's water supply with fertilizer or E.coli bacteria.

A cross-connection is when there exists a physical connection between a potable source of water and a source of contamination. The most worrisome cross-connection in our area is that of a culinary service line being connected into an irrigation main, and vice a versa, an irrigation service line being connected into a culinary main. Fortunately, neither of these have occurred in our District, but it has occurred in other areas. It usually results in people becoming very sick. The District monitors contractors very closely in order to prevent this sort of cross-connection.

There are other connections that are not technically cross-connections because they have a check valve, but the check valve system they have is not up to today's standards. One such connection is the *utah riser*. This fire suppression connection is actually allowed in businesses as long as they

were existing before new laws were put into place. Most of these fire sprinklers have propylene glycol in them to prevent freezing. The check valves that are on the *utah riser* are not up to current standards, but because it would cost the business owner so much to upgrade, the State lets them slide. The check valves on these risers can leak, and there is no means of testing them.

You will know your system is leaking, because there is a very distinctive smell and taste if there is propylene glycol in your water supply; it smells and tastes like a rotting onion has been soaking in the water. Even though propylene glycol isn't toxic, it is extremely unpleasant to drink or smell. If you have a sprinkler system in your place of business, and you start tasting and smelling onions in your water, chances are very high that your fire suppression system is leaking into your water supply. We would highly recommend not waiting until it leaks, however. Just get your *utah riser* replaced with a proper unit that can be tested annually.


You are required to have your backflow device tested by a certified technician every year. This report must be sent to the water department. It is imperative that you have installed the correct back flow device and that it is tested annually, and also that any potential cross-connections are discovered and remedied.



If you have any questions regarding potential cross-connections or backflow devices, please contact the water department.

POSSIBLE CONTAMINANTS IN THE WATER

Drinking water, *including bottled water*, may reasonably be expected to contain at least small amounts of some contaminants.



The sources of our drinking water include rivers, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Below are some of these contaminants that may be present in source water.

MICROBIAL CONTAMINANTS, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

INORGANIC CONTAMINANTS, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.



PESTICIDES and **HERBICIDES** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

ORGANIC CHEMICALS, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

RADIOACTIVE CONTAMINANTS can be naturally-occurring or be the result of oil and gas production and mining activities.

LEAD, if present in elevated levels, can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components from the meter to the home. When your water has been sitting for an extended period of time, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. The District's lead testing results are shown in the results section of this report. The District tries to sample from homes known to have galvanized service lines. If your service line is galvanized, it is highly recommended that you replace it.



For more information on lead in drinking water, contact the Safe Drinking Water Hotline at (1-800-426-4791), or visit <http://www.epa.gov/safewater/lead>.

RADON is a radioactive gas that you can't see, taste, or smell. It is found throughout the U.S. Radon can be released into the air via water, and then inhaled.

At this time, radon monitoring is not required by the EPA; however, the EPA is considering making radon monitoring a requirement. The proposed MCL for radon is 4,000 pCi/L for systems which have a public education program for radon.

The District tested its source water for radon in 2014, even though it was an unregulated contaminant. The results were as follows: the average level was 312 pCi/L; the low was 203 pCi/L; the high was 398 pCi/L. For additional information on radon, call EPA's Radon Hotline (1-800-SOS-RADON).

CRYPTOSPORIDIUM and **GIARDIA** are microbial pathogens found in surface water throughout the U.S. Although filtration removes cryptosporidium and giardia, the most commonly-used filtration methods cannot guarantee 100 percent removal. Monitoring conducted by Weber Basin indicates the presence of cryptosporidium and giardia in the raw water prior to treatment. Weber Basin uses UV light in the water treatment, which inhibits these organisms from reproducing and causing sickness.

Ingestion of cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people are at greater risk of developing life-threatening illness. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

CHROMIUM is an odorless and tasteless metallic element. Chromium is found naturally in rocks, plants, soil, volcanic dust, and animals. The most common forms of chromium that occur in natural waters in the environment are: Trivalent chromium (chromium-3) and Hexavalent chromium (chromium-6).

Chromium-3 is an essential human dietary element. It is found in many vegetables, fruits, meats, grains, and yeast.

Chromium-6 occurs naturally in the environment from the erosion of natural chromium deposits. It can also be produced by industrial processes. There are demonstrated instances of chromium being released to the environment by leakage, poor storage, or inadequate industrial waste

disposal practices.

Chromium 6 is the more toxic of the two forms of chromium. The District tested for Chromium 6 in 2014 and found no trace of this contaminant in its source water.

WHAT HAPPENED TO THE WATER IN FLINT, MICHIGAN?


The city of Flint changed its water supply to the Flint River that was naturally high in chloride. In the treatment process, the Flint treatment plant chose to use an iron chloride coagulant instead of a sulfate based coagulant, thereby raising the overall chloride levels in the water. Chloride is naturally corrosive. Due to the high chloride levels in the water, the iron water lines began to corrode at a rapid rate, releasing iron into the water. Chlorine, which is added to water to kill bacteria, began reacting with the high iron levels in the water, reducing the ability of the chlorine to disinfect. Because of this, Flint City began getting bacteria hits in their water samples. Because of the increase in the bacteria, the Flint treatment plant began adding even more chlorine, which in turn increased the corrosivity of the water even more, releasing even more iron, lead, and copper into the water.

The whole ordeal was a domino effect. It wasn't helped by the fact that many of the service lines in Flint are lead. The corrosivity of the water released very high levels of lead into the water due to these service lines.

WHAT HAPPENED TO THE WATER IN SANDY, UTAH?

The city of Sandy suffered an overfeed of fluoride due to a malfunctioning fluoride pump, which in turn lowered the water ph enough to dissolve metal. Heavy metals that were dissolved entered the distribution system causing some residents to become ill.

Sandy uses fluorosilicic acid while the South Davis Water District fluoridates using sodium fluoride. Sodium fluoride does not make the water ph drop like fluorosilicic acid. Sodium fluoride is an inert powder, however, there is still the danger of a fluoride overfeed. We are still not clear on how the fluoride pump continued to run while Sandy's well pump was off. Sandy has hired independent investigators to investigate this, but at the District's fluoridation sites, if the power to the well is off, it is also off at the fluoride pump.



We are anxious to find out how this occurred in Sandy, but in the meantime the District has created different scenarios trying to get the system to fail, and have not been able to duplicate what happened in Sandy. We will always continue to safeguard our system from potential overfeeds.

The water provided by the South Davis Water District meets or exceeds all EPA and Utah State water quality requirements. The treated surface water that the District purchases from Weber Basin has won numerous awards for water taste and quality.

We at the South Davis Water District are committed to providing our residents with the best possible drinking water. We do testing on our water that is not required by the State or the EPA, such as radon and chromium 6. We strive to go the extra mile with our water quality.

DEFINITIONS AND TERMS

The following are definitions for some terms and abbreviations that you may be unfamiliar with.

Detected Contaminant - Any contaminant detected at or above its minimum detection limit (MDL)

MDL - Minimum Detection Limit (The lowest level at which a particular contaminant is detected with a specified degree of certainty)

MCLG - Maximum Contaminant Level Goal (The level of a contaminant in drinking water below which there is no known or expected risk to health.)

MCL - Maximum Contaminant Level (The highest level of a

contaminant that is allowed in drinking water)

LRAA - Location-based running annual average

NA - Not applicable (there is no Federal or State MCL and/or MCLG)

ND - Not detected

NTU - Nephelometric Turbidity Unit (a measure of the cloudiness of the water)

ppm - parts per million, or milligrams per liter (mg/l)

ppb - parts per billion, or micrograms per liter (µg/l)

pCi/L - picocuries per liter (a measure of radioactivity)

The following page contains all of the regulated and unregulated drinking water contaminants that we detected during this year. We test for over 130 contaminants (i.e., pesticides, herbicides, organic compounds, etc.) with almost all being non-detectable.

Not all contaminants are required to be sampled for every year. The EPA and State of Utah have established that, in some circumstances, if a source of water goes a determined period of time without having detected certain contaminants, or the detected contaminants remain at consistently low levels for a determined period of time, that source may qualify for reduced monitoring.

Some of the surface water data, though representative, are more than one year old. Because the concentrations of certain contaminants do not change frequently, the state allows less frequent monitoring.

The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. These contaminants are harmful if ingested in certain amounts. The EPA determines these amounts for public water systems, and creates regulations that allow for a large cushion of safety. The FDA regulates limits for bottled water companies. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Contact Person

Jake Ferguson

801-295-4468

sdwoffice@southdaviswater.us

REGULATED INORGANIC CONTAMINANTS -- Data is derived from samples collected from 2012 through 2018.

<u>Contaminants</u>	<u>Average</u>	<u>Low</u>	<u>High</u>	<u>MCL</u>	<u>MCLG</u>	<u>Violation</u>	<u>Typical Sources</u>
Arsenic (ppb)	.00095	.0009	.001	10	NA	NO	Erosion of natural deposits; runoff from orchards.
Barium (ppm)	0.19	.06	0.38	2	2	NO	Erosion of natural deposits; discharge of drilling wastes.
Fluoride ¹ (ppm)	0.68	0.04	1.11	4	4	NO	Erosion of natural deposits; water additive.
Nitrate (ppm)	2.25	.27	3.4	10	10	NO	Runoff from fertilizer use; erosion of natural deposits.
Selenium (ppb)	0.19	0.0015	1.1	50	50	NO	Erosion of natural deposits; discharge from mines.
Sodium (ppm)	114	33	159	NA ²	NA	NA	Erosion of natural deposits.
Sulfate (ppm)	42	29	63	1,000 ³	NA	NO	Erosion of natural deposits.
Total Dissolved Solids (ppm)	755	432	1080	2,000	NA	NO	Erosion of natural deposits.
Lead (ppm)	0.0022	0.0005	0.0117	0.015	0	NO	Corrosion of plumbing; erosion of natural deposits.
Copper (ppm)	.136	.031	.497	1.3	1.3	NO	Corrosion of plumbing; erosion of natural deposits.
Cyanide (ppm)	0.004	0.003	0.005	0.2	0.2	NO	Discharge from metal, plastic, or fertilizer factories.
Total Chromium (ppm)	0.00025	ND	0.001	0.1	0.1	NO	Erosion of natural deposits.
Nickel (ppm)	0.002	ND	.009	0.1	0.1	NO	Erosion of natural deposits; discharge from factories.

¹Fluoride levels in the District are adjusted to maintain levels between 0.6 and 0.8 ppm.
²The State of Utah requires monitoring for sodium even though no MCL has been established.
³The MCL for sulfate and total dissolved solids is established by the State of Utah.

REGULATED ORGANIC CONTAMINANTS (DISINFECTION BYPRODUCTS) -- Data derived from 2018 samples.

<u>Contaminants</u>	<u>LLRA¹</u>	<u>Low</u>	<u>High</u>	<u>MCL</u>	<u>MCLG</u>	<u>Violation</u>	<u>Typical Sources</u>
Trihalomethanes (ppb)	31.6	11.6	40.1	80	NA	NO	By-product of drinking water chlorination.
Haloacetic Acids (ppb)	15.3	8.4	34.6	60	NA	NO	By-product of drinking water chlorination.

¹This value represents the running annual average for 2018.

REGULATED MICROBIOLOGICAL CONTAMINANTS -- Data derived from 2018 samples. (Bacteria testing derived from 120 samples)

<u>Contaminants</u>	<u>HMNP¹</u>	<u>MCL</u>	<u>MCLG</u>	<u>Violation</u>	<u>Typical Sources</u>
Total Coliform Bacteria	0	1 SAMPLE	0	NO	Naturally present in the environment.
Fecal Coliform & E. coli	0	1 SAMPLE	0	NO	Human and animal fecal waste.

<u>Contaminants</u>	<u>Percentage</u>	<u>Average</u>	<u>High²</u>	<u>MCL</u>	<u>Typical Sources</u>
Turbidity	100% ³	0.02 NTU	0.07 NTU	0.3 NTU	Sediments from runoff.

¹Highest monthly number of positive samples.
²This value represents the highest single measurement of combined filter readings taken every four hours during 2018.
³This value represents the lowest monthly percentage of combined filter readings meeting less than 0.3 NTU in at least 95% of the measurements taken each month during 2018.

REGULATED RADIOLOGIC CHEMICALS -- Data is derived from samples collected from 2013 through 2018.

<u>Contaminants</u>	<u>Average</u>	<u>Low</u>	<u>High</u>	<u>MCL</u>	<u>MCLG</u>	<u>Violation</u>	<u>Typical Sources</u>
Gross Alpha Particles (pCi/L)	5.6	1.2	13.4	15	0	NO	Erosion of natural deposits.
Combined Radium (pCi/L)	0.47	0.3	1.1	5	0	NO	Erosion of natural deposits.